



# Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster · windows  
 Rollläden · shutters  
 Türen + Tore · doors  
 Fassaden · curtain walling  
 Baubeschläge · building hardware

Version 1.en

**TEST CERTIFICATE NO. 15/11-A002-C1**

**Applicant** Işıldak İnşaat Taah. Tic. A.Ş.  
 Mutlukent Mah.1986 Sk. No:20  
 Ümitköy-Ankara-Türkiye

**Test date** January 06, 2016

**Product name** **Albert Genau Tiara 08**

**Type** Fully glazed sliding door with glazed panels made of 8mm tempered glass as balcony glazing with stacking area, freely selectable number of glazed panels (3panels), the first glazed panel opens on hinges.

**Dimension** (W x H) max. 2400 mm x 2200 mm

**Performance** According to test report No. 15/11-A002-B1 from February 02, 2016:

Air permability according to EN 12207 **Class 2**

Water Tightness according to EN 12208 **Class 2A**

Impact Resistance according to EN 14019 **Class I2/E5**

Measurement of deflection **+1200 Pa: 49,3 mm.**  
 According to EN 12211/12210 (class 3) **-1200 Pa: 55,5 mm.**

Repeated pressure **+600 Pa / -600 Pa**  
 According to EN 12211/12210 (class 3)

Safety test **+1800 Pa / -1800 Pa**  
 According to EN 12211/12210 (class 3)

**Validity** Period of validity of standarts

Y. Altuq  
 Technical Manager



February 02, 2016

PFB GmbH & Co. Prüfzentrum für Bauelemente KG  
 AG Traunstein HRA 8871  
 Lackermannweg 24, 83071 Stephanskirchen  
 pHG PFB Verwaltungs GmbH  
 Geschäftsführer: Matthias Demmel, Rüdiger Müller  
 AG Traunstein HRB 16490

Telefon +49 (0) 80 36 / 67 49 47 0  
 Telefax +49 (0) 80 36 / 67 49 47 28  
 www.pfb-rosenheim.de  
 info@pfb-rosenheim.de

Sparkasse Rosenheim  
 Bankleitzahl 711 500 00  
 Kontonummer 500 556 741  
 Steuer-Nr.156/172/13009  
 USt-IdNr. DE245353602

Anerkannte Prüfstelle  
 Landesbauordnung  
 BAY 33  
  
 Notified Body  
 No. 1644





# Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster · windows  
Rollläden · shutters  
Türen + Tore · doors  
Fassaden · curtain walling  
Baubeschläge · building hardware

**TEST CERTIFICATE NO. 18/04-A002-C1**

Version 1.en

**Applicant** Işıldak İnşaat Taah. Tic.A.Ş.  
Mutlukent Mah.1986 Sk.No:20  
Ümitköy-Ankara-Türkiye

**Test date** May 30, 2018

**Product name** **Albert Genau Slidemaster Twin**

**Type** Fully glazed sliding door with glazed panels made of double glass (3 panels)(4-12-4 / Tempered)

**Dimension** (W x H) max. 2400 mm x 2200 mm

**Performance** According to test report No. 18/04-A002-B1 from June 11, 2018:

Air permability according to EN 12207 **Class 2**

Water Tightness according to EN 12208 **Class 3A**

Impact Resistance according to EN 14019 **Class I2**

Measurement of deflection **+1600 Pa: 54,5 mm.**  
According to EN 12211/12210 (class 4) **-1600 Pa: 53,9 mm.**

Repeated pressure **+800 Pa / -800 Pa**  
According to EN 12211/12210 (class 4)

Safety test **+2400 Pa / -2400 Pa**  
According to EN 12211/12210 (class 4)

**Validity** Period of validity of standarts

Y. Altuq

Technical Manager



June 25, 2018

PfB GmbH & Co. Prüfzentrum für Bauelemente KG  
AG Traunstein HRA 8871  
Lackermannweg 24, 83071 Stephanskirchen  
phG PfB Verwaltungs GmbH  
Geschäftsführer: Matthias Demmel, Rüdiger Müller  
AG Traunstein HRB 16490

Telefon +49 (0) 80 36 / 67 49 47 0  
Telefax +49 (0) 80 36 / 67 49 47 28  
www.pfb-rosenheim.de  
info@pfb-rosenheim.de

Sparkasse Rosenheim  
Bankleitzahl 711 500 00  
Kontonummer 500 556 741  
Steuer-Nr. 156/172/13009  
USt-IdNr. DE245353602

